



Cable Innovations, Inc.
130 Stanley Ct.
Lawrenceville, GA 30045
770-962-5146
www.Cableinnovations.com

INSTALLATION INSTRUCTION FOR DIU-15D-1

* New Installation:

1. Mount the DIU-15D-1 to the structure using the two 1/4" Hex head screws provided, with the three F connectors facing down (see figure 1). This will help keep the water out of the cable connectors.
2. It is very important that the DIU-15D-1 is connected to a very good ground system preferably the power service grounding electrode system. The ground wire should be at least #12 copper. The grounding conductor should be run to the grounding electrode (rod) in as straight a line as possible. If bends are needed make the bend radius not less than 4". Insert the wire under the grounding screw of the unit, and make sure that the wire is tightly secured under the screw.
3. Connect the cable to the DIU-15D-1 making sure to have drip loops, see figure 1.

* Existing Installation:

1. Remove the cables from the grounding block and remove the grounding block from the installation. Use the new installation instructions from this point on.

FIGURE 1



